

DOCUMENT 00 21 14

QUESTIONS ON BID DOCUMENTS (QBD)

Potential Bidders must complete this QBD Form and submit to the address below no later than 4:00 PM and three (3) business days before the bid opening date.

Project: PIER 80 MOORING AND BERTHING
IMPROVEMENTS

Contract No. 2871

To: Port of San Francisco
Pier 1
San Francisco, CA 94111
Phone: (415) 274-0526
Attention: **Noel Aquino**
Email: constructionbids@sfport.com

City Use Only	
QBD No.	006
Received by:	Noel A.
Date Received:	4/4/25
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent	
Response:	4/8/25



CONTRACTOR'S QUESTIONS			
Company Name:	Power Engineering Construction	Date	4/4/2025
Contact Name:	Sharon Rowe	Tel:	714-290-1260
Title:	Estimator	Fax:	
<i>Check One Only (Use separate form for each specifications and drawing question.)</i>			
<input type="checkbox"/> Spec. Section:		Paragraph(s):	
<input checked="" type="checkbox"/> Drawing Sheet:	S-508 & S-208	Detail(s):	
Question: Please confirm if the Port is able to provide a detail of the relocation of the PUC water meter.			

CITY'S REPLY	
<input type="checkbox"/>	Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.
Reply: Contractor to follow CBC 2022 code requirements for installation. For further clarification for information already in the drawings, see attached sketch.	
By: Max/Allison	Bureau/Firm: SGH
Date: 4/8/25	


The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.

NOT FOR CONSTRUCTION - ISSUED FOR BID

Existing PUC Water Meter - Strut Channel Connection
Please relocate the existing PUC Water Meter approximately 29 ft to the east.
Relocate in accordance with current plumbing code. Please see below for some overall
photos of the existing strut channel connection.



**7 PARTIAL DEMOLITION PLAN
ALTERNATE BID ITEMS** SCALE: 1"=10'-0"



KEY PLAN

FRANCISCO PORT COMMISSION RT OF SAN FRANCISCO DEPARTMENT OF ENGINEERING	DESIGNED: DATE: ACD/MLA 02/10/25	APPROVED BY SAN FRANCISCO PORT COMMISSION DATE: _____ _____ CHIEF HARBOR ENGINEER	PORT OF SAN FRANCISCO PIER 80 MOORING AND BERTHING IMPROVEMENTS	CONTRACT NO. 2871
	DRAWN: DATE: RTB 05/05/23			DRAWING NO. 22142-80-S
	CHECKED: DATE: WMB 02/10/25		PARTIAL DEMOLITION PLAN SHEET 7	SHEET NO. S-208 13 OF 27