

## DOCUMENT 00 21 14

## QUESTIONS ON BID DOCUMENTS (QBD)

*Potential Bidders must complete this QBD Form and submit to the address below no later than 4:00 PM and three (3) business days before the bid opening date.*

Project: PIER 80 MOORING AND BERTHING  
IMPROVEMENTS

Contract No. 2871

To: Port of San Francisco  
Pier 1  
San Francisco, CA 94111  
Phone: (415) 274-0526  
Attention: **Noel Aquino**  
Email: [constructionbids@sfport.com](mailto:constructionbids@sfport.com)

City Use Only	
QBD No.	013
Received by:	Noel A.
Date Received:	4/8/25
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	4/8/25

CONTRACTOR'S QUESTIONS	
Company Name: Manson Construction Co.	Date 4/7/2025
Contact Name: ESTIMATING	Tel: 510-775-3204
Title: _____	Fax: _____
<i>Check One Only (Use separate form for each specifications and drawing question.)</i>	
<input type="checkbox"/> Spec. Section: _____	Paragraph(s): _____
<input checked="" type="checkbox"/> Drawing Sheet: S-206	Detail(s): _____
<p><b>Question:</b> Both the bid form in Section 00 41 00 and Sheet S-501 indicate there are 15 EA fenders in the base bid scope. Each fender should get a new reaction wall to support its installation. Sheet S-206 does not show any demo limits at STA 22+33E where the most northern fender on the East Berth is shown on S-501. Please clarify that there are 15 new fenders on the East Berth and every location requires a new reaction wall per S-601 details. If so, please revise S-206 to indicate the required demo limits.</p>	

CITY'S REPLY
<input type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.
<p><b>Reply:</b></p> <p>Addendum to follow to clarify that 15 fenders and reaction walls to be installed and for bull rail demo limits.</p>
<p>By: Max/Allison      Bureau/Firm: SGH      Date: 4/8/25</p>

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.