

DOCUMENT 00 21 14

QUESTIONS ON BID DOCUMENTS (QBD)

Potential Bidders must complete this QBD Form and submit to the address below no later than 4:00 PM and three (3) business days before the bid opening date.

Project: FISHERMAN'S WHARF FORWARD-TAYLOR STREET PUBLIC PLAZA

Contract No. 2894

To: Port of San Francisco
 San Francisco, CA
 Attention: Chris Horiuchi
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	10
Received by:	
Date Received:	10/27/2025
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	10/29/2025

CONTRACTOR'S QUESTIONS

Company Name: CAZADORO CONSTRUCTION Date: 8/27/25
 Contact Name: FISHERMAN'S WHARF PLAZA Tel: (510) 715-0152
 Title: PROJECT MANAGER Fax: (415) 439-4340

Check One Only (Use separate form for each specifications and drawing question.)

Spec. Section: 03 30 50 Paragraph(s): 3.5.C 3.12
 Drawing Sheet: _____ Detail: _____

Specification Section 03 30 50, paragraph 3.5.C says All floors shall receive a steel trowel finish unless otherwise noted. Refer to Article 3.12.

Article 3.12 Tabel 1 Finishes for Slab Surfaces notes that floors have a trowel finish.

Does the main plaza slab get a steel trowel finish or a regular wood trowel finish?

CITY'S REPLY

Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.

Reply:
 Provide wood trowel finish, see updated specifications.

By: N. Gilmore Bureau/Firm: Arcadis Date: 10/29/2025

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.