

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE
IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
Pier 1
San Francisco, CA 94111
Phone: (415) 274-0526
Attention: **Noel Aquino**
Email: constructionbids@sfport.com

City Use Only	
QBD No.	023
Received by:	Noel A.
Date Received:	8/2/24
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent Response:	

BIDDER'S QUESTION	
Company Name: <u>Marina Landscape Inc.</u>	Date: <u>8/1/2024</u>
Contact Name: <u>Farzad Menhaji</u>	Tel: <u>(714) 939 6600</u>
Title: <u>Soil Preparation</u>	Fax: _____
Check One Only (Use separate form for each specification and drawing question.)	
<input type="checkbox"/> Spec. Section: <u>329119</u>	Paragraph(s): <u>3.02H & 3.03A</u>
<input type="checkbox"/> Drawing Sheet: <u>L-2</u>	Detail(s): _____
<p>Question: Since all planting areas and tree wells are to receive either import soil or structural soil per materials legend on sheet L-2, confirm that in situ soil preparation per part 3.02H and amended backfill for planting areas per part 3.03A of section 329119 are not required.</p>	

CITY'S REPLY	
<input checked="" type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.	
<p>Reply: Spec section 32 91 19, Planting Preparation pertains to all planting soils EXCEPT at Stormwater tree wells. Parts 3.02H and 3.03A of section 32 91 19 may be relevant depending on soils test results per same spec section. Stormwater tree wells will receive structural soils per Spec section 32 91 13 Structural Soils.</p>	
By: <u>Julie An</u>	Bureau/Firm: <u>Bureau of Landscape Architecture</u> Date: <u>8/6/2024</u>

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.