

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE
IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
Pier 1
San Francisco, CA 94111
Phone: (415) 274-0526
Attention: **Noel Aquino**
Email: constructionbids@sfport.com

City Use Only	
QBD No.	037
Received by:	Noel A.
Date Received:	8/21/24
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent Response:	8/22/24

BIDDER'S QUESTION

Company Name: Delao Electric Inc Date 8/21/24
 Contact Name: Jorge Cerdas Tel: 415-681-7011
 Title: Estimator Fax: _____

Check One Only (Use separate form for each specification and drawing question.)

☐ Spec. Section: 26 05 33.26 Paragraph(s): 1.01 H & I / 1.02
☐ Drawing Sheet: _____ Detail(s): _____

Question:

Is it necessary for this project to obtain the Manufacturer's on site services for this project pertain the PGRS Conduit System. Or is it sufficient with just having the installer been certified by PGRS Manufacture. If Manufactures on site service is required, this will subsequently will increase the cost.

CITY'S REPLY

☐ Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.

Reply: It is sufficient to have the installers be certified by the PGRS Manufacturer with a valid, unexpired Installer Certificate by the PGRS Manufacturer.

By: Simon T. Bureau/Firm: Public Works/ Electrical Date: 8/21/2024

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.